

ADDENDUM #3

Owner:
Montana State University
Facilities Management
Owner Rep: Donny Beebe
Project Manager, PDC

Architect:
Architects Alaska, Incorporated
347 S Ferguson Ave, Suite 3
Bozeman, Montana 59718
Project Architect: Thomas Brown

NOTICE TO BIDDERS

This Addendum is issued pursuant to the Instructions to Bidders. This Addendum serves to clarify, revise, and supersede information in the Contract Documents and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.

The Bidder shall acknowledge receipt of this Addendum on the Bid Form.

The Date for receipt of bids is unchanged.

BIDDER QUESTIONS

Question 1 Do the beams shown in the image below along the entire existing gable end wall need to be removed, or can the beams stay in place?



Answer 1 The glu-lam beam(s) are to be removed and reused at the new gable end, the beams primarily provide lateral support. The truss at the current gable end above the beam(s) to be removed and reused at the new gable end. The new truss layout would start at the same location as the existing gable end truss.

ATTACHMENTS

NONE

END OF ADDENDUM